



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20234052	Date:	June 25, 2024
Project Title:	DOUGLAS CORNER	Applicant:	
Location:			
150 NE TUDOR RD, LEES SUMMIT, MO 64086		ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	UC	KANSAS CITY, MO 64116	
Description:	NEW SHELL BUILDING FOR FUTURE	Primary: (913) 888-0647	
TENANTS			
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Released for Construction

1. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.