CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234141

Address: 400 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground Electrical Mitchell Schwarz Failed Tuesday, June 25, 2024

Inspection - Commercial

Corrective Action Required:

1 Misc -Pot hole along cover underground conduit for light pole bases. Ensure all

Conduit in green space is 18" below grade.

-ensure conduit under driving surface to be 24" below sub grade. As

discussed on site.

Comments: