

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20234141  
Address: 400 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Mitchell Schwarz	Failed	Tuesday, June 25, 2024

Corrective Action Required:

1	Misc	-6x6 posts as required by plans -sister all over notched exterior wall studs for anchor bolts -missing king studs at window opening NE exterior wall corner -install Simpson PHD2-SDS3 hold downs per plans (at each 6x6) -address top plates throughout not tied together -provide web stiffeners for double joist hangered i-joist -have engineer address hold down for iJoist
---	------	--

**Comments:**