

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20231141
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Punch List Inspection	Nick Scott	Partial	Tuesday, June 25, 2024

Corrective Action Required:

1 6-24-24 NS site visited for a TCO which can be granted
Punch list
-Ground needs vegetation
-fire hydrant 017-155 needs to be lowered to under 6 inches to grade
-on the east side needs to have the two valves lowered to grade
-both sides of where the water tie ins sidewalks need to be put back the east side needs 5 panels from what I see on google maps street view. west side needs one panel.

Comments: