



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20240118	Date:	June 26, 2024
Project Title:	JOHN KNOX VILLAGE - COURTYARDS	Applicant:	
BUILDING E			
Location:		JOHNSON CONTROLS, INC	
515 NW MOORE ST, LEES SUMMIT, MO 64081		9850 LEGLER RD	
Type of Work:		LENEXA, KS 66219	
Occupancy Group:	R-2	Primary:	(913) 307-4392
Description:	JOHN KNOX VILLAGE -		
COURTYARDS BUILDING E - SENIOR LIVING			
INDEPENDENT LIVING APARTMENTS			
Construction Type:	Type VA (1 hour)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Rejected

1. Provide notification in residence living spaces.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.