



FIRE DEPARTMENT

**Prevention Division
(816)969-1300**

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20240118	Date:	June 26, 2024
Project Title:	JOHN KNOX VILLAGE - COURTYARDS BUILDING E	Applicant:	
Location:	515 NW MOORE ST, LEES SUMMIT, MO 64081		ALL SAFE FIRE PROTECTION LLC
Type of Work:			6603 ROYAL ST STE D
Occupancy Group:	R-2		PLEASANT VALLEY, MO 64068
Description:	JOHN KNOX VILLAGE - COURTYARDS BUILDING E - SENIOR LIVING INDEPENDENT LIVING APARTMENTS	Primary:	(816) 492-7202
Construction Type:	Type VA (1 hour)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Sheet 1 shows Fire Dept Conn as a "4" OUT TO "4x2½ x 2½". This need to be a 4" storz with a 30 degree elbow.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.