

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236605
Address: 3832 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Thursday, June 27, 2024

Corrective Action Required:

2	Miscellaneous Correction	3832 SW Ravengate. Occupancy (3) -Sump pump extension is not installed -Sod and splash pads are not installed -Seal penetration in siding at gas line -Exterior grading has not been completed for a plot plan inspection -Plot plan must pass
---	--------------------------	---

Okay for TCO only

Comments: