CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240644

Address: 1617 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Driveway Inspection Dustin Agcopra Partial Friday, June 28, 2024

Informational:

1 Misc 6-28-24 Dustin A, DW is formed and compacted to city specs. Curb has been

dowled. Informed contactor white cure needed to be added to curb.

Approved to pour.

Comments: