

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242325  
Address: 2135 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Robb Popp	Failed	Monday, July 01, 2024

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	7/1/24 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -RESTORE SILT FENCE -PROTECT STORM INLET -PROVIDE EROSION CONTROL METHODS AT SPOILS PILE ON ADJACENT LOT **STOP WORK WILL BE ISSUED IF NOT IN COMPLIANCE
---	----------------------------	--

**Comments:**