



FIRE DEPARTMENT

**Prevention Division
(816)969-1300**

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20242441	Date:	July 01, 2024
Project Title:	LEES SUMMIT COMMERCE CENTER - H & R BLOCK DEPOT	Applicant:	
Location:	1220 NW MAIN ST, Unit:E, LEES SUMMIT, MO 64086	ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	S-1	KANSAS CITY, MO 64116	
Description:	H & R BLOCK - OFFICE AND WAREHOUSE SPACE FOR IT AND COMPUTER WORK. COMPUTER/IT ITEMS STORED AT THIS FACILITY	Primary: (913) 888-0647	
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Released for Construction

1. 25.2.1.4.1 Where modification is made to an existing system affecting more than 20 sprinklers, the new portion shall be isolated and tested at not less than 200 psi (13.8 bar) for 2 hours.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.