

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20215636  
Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector:  | Outcome: | Date:                 |
|----------------------------------|-------------|----------|-----------------------|
| <b>Sanitary Sewer - Air Test</b> | Devon Perry | Passed   | Monday, July 01, 2024 |

Informational:  
1 Misc 7-1-24. DP. All air testing has been completed.

**Comments:**