

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20215636
Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Devon Perry	Passed	Monday, July 01, 2024

Informational:	
1 Misc	All vacuum testing is complete
Corrective Action Required:	
2 Miscellaneous	6-7-24 DP.
Correction	MH 16-008 failed
	MH 16-009 needs backfilled
	MH A-4 failed

Comments: