

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240055
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Devon Perry	Passed	Tuesday, July 02, 2024

Informational:
1 Misc 7-1-24 DP. Crew has had the taps completed by the LS water department. They have all meters set. They couldn't get the full 10' copper tailpiece out of the back of the meter, but they do have a few feet as they stubbed Poly out of the building foundation. This was communicated and approved through Brent with LS Water.

Comments: