

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20236555
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Devon Perry	Passed	Tuesday, July 02, 2024

Informational:
1 Misc 6-18-24 DP. Took first sample on 8" and 6" to Blue Valley Lab.
6-19-24 DP. First sample on the 6" fire line passed. First sample on the 8" line failed TC+

Comments: