

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------------|----------|------------------------|
| Erosion Sediment Control (ESC) Inspection | Patrick Schonfeldt | Failed | Tuesday, July 02, 2024 |

| | |
|----------------|---|
| Informational: | |
| 1 | Misc |
| | 7-2-24 |
| | - Place gutter buddy at corner arboridge/150 to protect inlet |
| | - clean mud from streets and any mud build up at gutter buddies at storm inlets |
| | - clean mud that has washed across sidewalk at 150 from site. Add additional erosion control if grass buffer will not contain erosion |

Comments: