

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242738
Address: 2225 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Tuesday, July 02, 2024

Corrective Action Required:

1	Misc	-Remove enamel at bonding connection and tighten the screw -Isolate the feeder EGC from the grounded conductor -Too many conductors inside raceway at subpanel subjected to de-rating -Color EGC at subpanel with green tape
---	------	---

Comments: