

DEVELOPMENT SERVICES

Residential Plan Review

July 02, 2024

BUDDEMEYER CONSTRUCTION 616 SW BENJAMIN PL LEES SUMMIT, MO 64081 (816) 419-3526

Permit No:	PRRES20243136
Plan Name:	
Project Address:	1408 NE ERNEST WAY, LEES SUMMIT, MO 64086
Parcel Number:	5272028060000000
Location:	FRITCHIE BLUFFLOT 15
Type of Work:	NEW SINGLE FAMILY
Occupancy Group:	RESIDENTIAL, ONE- AND TWO-FAMILY
Description:	NEW HOUSE. FINISHED/UNFINISHED BASEMENT. WALKOUT BASEMENT. SUSPENDED SLAB. ROOF
	TRUSSES - DEFERRED. UNCOVERED DECK WITH METAL FRAMING.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Residential Plan Review Reviewed By: Andrea Sessler Not Received

1. Provide square footage of living area, garage area, unfinished basement area, etc (IRC Section R304)

PLEASE LIST AREA SQUARE FOOTAGES ON THE PLANS.

2. Identify type of roof/truss package (if used) complete with layout, component design, fastening details, blocking and sheathing requirements. (IRC Section 802.10)

DEFERRED

3. Provide combustion air calculations and specify transfer air grilles for fuel burning appliances located in confined space(s). (IRC Chapter 17 and Section G2407)

4. Designate R-value(s) for floors, walls, ceilings, roof/ceilings. (LSCO 7-802)

5. Designate use of each room or space including but not limited to; basement storage, garages, and attic areas intended for storage space.

220 SE Green Street | Lee's Summit, MO 64063 |816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

PLEASE LABEL GARAGE.

6. Detail required separation between garage and living area including door, door closer and gypsum board. (IRC R302.5)

PLEASE LABEL DOOR AND DOOR CLOSER DETAIL.

7. Beam and column locations, sizes and material.

SUSPENDED SLAB DESIGN NEEDS TO BE SUBMITTED.

8. Location of vertical supports for beams. (point loads)

SUSPENDED SLAB DESIGN NEEDS TO BE SUBMITTED.

9. Concrete reinforcement size and spacing.

SUSPENDED SLAB DESIGN NEEDS TO BE SUBMITTED.

10. Concrete thickness.

SUSPENDED SLAB DESIGN NEEDS TO BE SUBMITTED.

11. Concrete minimum compressive strength. (IRC Section 402.2)

SUSPENDED SLAB DESIGN NEEDS TO BE SUBMITTED.

12. Provide size, spacing, species and grade of dimensional floor joists.

13. Identify location, size, and material of all beams, girders and vertical supports.

14. Identify joists under bearing partitions. (IRC Section R502.4)

15. Identify type of protection used in unfinished areas under floor trusses. (IRC Section R302.13)

PLEASE LIST PROTECTION TYPE IF USING ENGINEERED JOIST SYSTEM.

16. Identify type of joist package or floor truss package (if used) complete with layouts, fastening details, blocking and bracing requirements and minimum sheathing.

PLEASE CLARIFY IF ENGINEERED JOISTS WILL BE USED. IF SO, PLEASE CORRECT APPLICATION AND IF THEY WILL BE DEFERRED OR NOT.

17. Specify acceptable material and size of exterior sheathing. (IRC Section R703)

18. Provide details for any walls over 10 feet in height. Include stud grade, size, spacing and actual, uninterrupted height. (IRC Section 602.3.1 and Table 602.3(5) & 602.3.1)

19. Identify interior load bearing walls. (IRC Section R602)

20. STEEL DECK DESIGN WILL NEED TO BE SUBMITTED IN ADDITION SHOWING CONSTRUCTION DETAILS.

Plot Plan Review Reviewed By: Andrea Sessler Rejected

220 SE Green Street | Lee's Summit, MO 64063 |816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

3. 100-year floodplain, where applicable, must be shown on the plot plan. (Foundation elevation certificate required prior to occupancy)

PENDING ENGINEER REVIEW - The plot plan should show an approximation of the floodplain/floodway.

4. WALL AS NEEDED WILL NEED DESIGNED OVER 48".

Planning Review RES	Reviewed By:	Not Required

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:					
Residential, Decks		1078			
Residential, Finished basements		1550	1550		
Residential, garage		528	528		
Residential, Un-Finished basements		410	410		
Residential, Living Area (Not Finished I	Basement)	1850	1850		
Roofing Material		Number of Bathrooms	4		
Number of Bedrooms	4	Number of Stories	1		
Number of Living Units	1	Total Living Area	3400		