

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242541
Address: 3929 SW FLINTROCK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Kyle Beard	Failed	Tuesday, July 02, 2024

Corrective Action Required:

1	Miscellaneous Correction	Piers were noted on the footing inspection but did not provide enough information on them. Please submit the following information on the piers and then reschedule a footing inspection A) quantity B) location C) size D) depth
---	-----------------------------	---

Comments: