

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231814  
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Tuesday, July 02, 2024

Corrective Action Required:

1	Misc	-Approval required from: Fire, Planning, Field Engineer, Water -Fire caulk riser penetration of fire pump room ceiling
---	------	---

**\*\*Fire and Water dept not OK for TCO.**

**Comments:**