

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235952
Address: 1932 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Wednesday, July 03, 2024

Corrective Action Required:

1	Misc	-Complete final grade, sod, downspouts, splash blocks and sump extension -Seal top of meter can -Min 2" clearance required from siding to concrete exposed to weather at front porch -No pier inspection for deck piers poured in buckets
---	------	--

Comments: