

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234924
Address: 2782 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, July 03, 2024

Corrective Action Required:

1	Misc	2782 SW 12 Street
---	------	-------------------

- Fb = Fire block/draft stop
- Fb top of chase at laundry/ garage entry
 - Missing LIB's primary bedroom and garage walls
 - Provide Boca plate primary shower water supply
 - Missing many double joist in basement
 - No gas piping installed
 - Not a complete list, do not call in until all MEP's are complete

Comments: