

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223975
Address: 204 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Curb Construction	Dustin Agcopra	Passed	Wednesday, July 03, 2024

Informational:

1	Misc	5-28-24 Dustin A, Curb is all poured to city specs. Informed Dutch there was 2 areas that washed out underneath that would need to be filled in. 5-29-24 Dustin A, few cracks in curb 6-10-24 Dustin A, 2 curbs are cracked 7-3-24 Dustin A, Cracks are hairline and have not separated so still in compliance.
---	------	--

Comments: