

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223975
Address: 204 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Storm Sewer Construction Inspection	Dustin Agcopra	Passed	Wednesday, July 03, 2024

Informational:

1	Misc	1-30-24 Dustin A, Contractor on site working on storm on south side of building. MH 2 and 5A is installed at the correct slopes . 2-23-24 Dustin A, Started working on underground retention. 3-20-24 Dustin A, Storm retention manhole was knocked off. There is gravel that will need to be cleaned out and mastic reapplied.
---	------	---

Comments: