

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242665
Address: 3804 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Kyle Beard	Failed	Wednesday, July 03, 2024

Corrective Action Required:

1	Miscellaneous Correction	Inspection denied until mud and gravel in the streets are cleaned up. Full erosion control measures must be maintained until CofO
---	--------------------------	--

Comments: