



## FIRE DEPARTMENT

Prevention Division  
(816)969-1300

### PLANS REVIEW CONDITIONS

Permit No:	PRCOM20235207	Date:	July 03, 2024
Project Title:	RESIDENCES AT BLACKWELL - BUILDING #3	Applicant:	
Location:	2931 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063	ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	R-2	KANSAS CITY, MO 64116	
Description:	RESIDENCES AT BLACKWELL - BUILDING #3 - 67 Units	Primary:	(913) 888-0647
	NEW APARTMENT BUILDING		

PERMITTED WORK - FOUNDATION AND UNDERSLAB  
Construction Type: Type VA (1 hour)  
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

#### Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Fire department connection shows 2 - 2½" siamese connection. FDC needs to be a 4" storz with a 30 degree elbow.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.