

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241190
Address: 2134 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, July 03, 2024

Corrective Action Required:

3	Miscellaneous Correction	Builder asked for the exterior garage portal sheeting inspection only. -As stated by the inspector from the last inspection. Exterior garage sheeting must be nailed to both top plates. Have full erosion control measures in place before rescheduling all rough inspection
---	--------------------------	---

Comments: