

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240962
Address: 1925 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Kyle Beard	Failed	Wednesday, July 03, 2024

Corrective Action Required:

2	Miscellaneous Correction	Pier holes are full of water -Remove water and reschedule for inspection
---	--------------------------	---

Inspectors usually can not give you an exact time of inspection. Have all work completed before scheduling a inspection

Time 1:38 pm. KBEARD

Comments: