

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242325
Address: 2135 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Friday, July 05, 2024

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	7/5/24 -RESTORE SILT FENCE -PROTECT STORM INLET -PROVIDE EROSION CONTROL METHODS AT SPOILS PILE ON ADJACENT LOT
---	----------------------------	--

Comments: