

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242541
Address: 3929 SW FLINTROCK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Kyle Beard	Failed	Friday, July 05, 2024

Corrective Action Required:

1	Miscellaneous Correction	Water line has been run out from under the foundation to a point of 20 feet towards the street Okay to cover
---	-----------------------------	--

This is a partial pass only

Water failed due to the footing inspection not passing

Comments: