

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241065

Address: 3728 SW KNOXVILLE CT, LEES SUMMIT, MO 640823730 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Kyle Beard	Failed	Tuesday, July 09, 2024

Corrective Action Required:

1	Miscellaneous Correction	Gas on both units failed because of gauge reading 0 psi at the beginning of the inspection
---	--------------------------	--

Comments: