

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20233869  
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Storm Sewer Construction Inspection</b>	John Jackson	Partial	Tuesday, July 09, 2024

Informational:

1	Misc	06/27/24 Thursday JMJ (ICON) Contractor demo exist storm box to prepare to install new box. Contractor is work to drain project of rainwater so they can install storm pipe.
		07/09/24 Tuesday JMJ (ICON) Contractor installed 1B, 2B, & 3B and 15" HDPE as pre plan. 2B installed the 1" orifice plate toward the existing pipe.

**Comments:**