

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242541
Address: 3929 SW FLINTROCK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Wednesday, July 10, 2024

Corrective Action Required:

2	DCM2 ESC	7/10/24
	DEFICIENT	-Maintain gravel filter with min 6" lift of min 3/4" gravel
	INSTALLATION	-Remove loose trash on site

Comments: