

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20234377
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Patrick Schonfeldt	Partial	Wednesday, July 10, 2024

Informational:
1 Misc 7-10-24 PS Inspected contractor perform air test on sanitary lines

A-1 to A-2 Passed

A-2 to A-3 Passed

Comments: