

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241136
Address: 3237 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, July 11, 2024

Corrective Action Required:

1	Misc	-have engineer address multiple top plates (fix to engineer specifications, missing nails in straps , incorrect screws used,) -seal rear garage wall and chase to ceiling space and furr down -address holes drilled closer than 2" to one another throughout (no engineering for fix uploaded or on site) -missing hold down device at stair landing exterior wall corner(still being installed)
---	------	--

Comments: