

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240309
Address: 3736 SW CLAYTON PL, LEES SUMMIT, MO 640823738 SW CLAYTON PL, LEES SUMMIT, MO
640823740 SW CLAYTON PL, LEES SUMMIT, MO 640823734 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Not Ready	Thursday, July 11, 2024

Corrective Action Required:

1	Miscellaneous Correction	Fall protection is not provided on any of the four units at the dining/great room sliding door
---	--------------------------	--

Install fall protection before rescheduling occupancy inspection

All units are not ready for inspection

Comments: