

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216100  
Address: 4813 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Plot Plan Inspection</b>	Khanh Nguyen	Failed	Thursday, July 11, 2024

Corrective Action Required:

1	Misc	Provide a swale at the back side of the lot flowing into the storm inlet at SE corner of lot. The storm inlet is currently covered with grading and must be uncovered
		Do not sod the lot

**Comments:**