

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240055
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Friday, July 12, 2024

Corrective Action Required:

1	Misc	*OK TO INSULATE
		UNITS A/B
		-OK
		UNIT C/D
		-OK
		UNIT E/F
		-Secure mc near doorway
		UNITS G/H
		-Install stud shoes at overbored studs for dwv

Comments: