

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20231450

Address: 410 NW CHIPMAN RD, LEES SUMMIT, MO 64086400 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>		Passed	Friday, July 12, 2024

Informational:

1 Misc

06/26/24 Wednesday JMJ

Sidewalk forms and materials were laid.

06/27/24 Thursday JMJ

Sidewalk to the Southeast of the project was poured early in the week.

The sidewalk passed the inspection slope % inspection.

07/12/24 Friday JMJ

Contractor poured sidewalk that runs along the Northside of project.

Side walk passed inspection: note on the Northwest side of of ramp there some high variants in cross slope, but not enough to fail with difficult angles and steep grades. Inspector compared cross slopes of existing sidewalk ramps to West and founded higher variants of cross slopes.

**Comments:**