



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113619, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---------------------------------|------------|----------|-------------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Above Ceiling Inspection | John Borns | Partial | Wednesday, September 21, 2011 |

Corrective Action Required

1 MISC

ENSURE ALL HVAC DUCT INSULATION JOINTS ARE TAPED

Corrective Action Required

2 MISC

SPRINKLER FIRE PROTECTION PIPING: SUPPORT DROP PIPING AT/NEAR CHANGES OF DIRECTION TO PREVENT STRESS TO FITTINGS. DO NOT HANG FROM JOIST TOP CHORD BRIDGING.

Corrective Action Required

3 MISC

OK TO PLACE ACT BORDERS LESS THAN OR EQUAL TO 2' FROM WALLS

Comments: