

	110cd Q C2-01	
	CONSTRUCTION TYPE: V-B	
	OCCUPANCY Groups: F-1	
	B LEVELS:1	
	PROJECT SQUARE FOOTAGE:61,504	
	Central Station Service-Alarm Central	
	Central Station Service-Alarm Central	
	This system designed	
	and installed according to	
	NFPA 72 2018-IBC 2018	
	& IFC 2018 SECTION 907	
	Fire Alarm Symbols NFPA-170 2015	
	Item Description	
	NAC Remote Power Supply	
	EOL End Of Line Resistor	
	S Photoelectric Smoke Detector	
	30cd Alarm Strobe/Ceiling Mount	
	Harm Strobe/Wall Mount	
	30cd Alarm Horn/Strobe Ceiling Mount	
	Alarm Horn/Strobe Wall Mount	
	Relay Module	
		₩
	1/8 th = a foot	
	15' 30' 45'	
	BUILDING IS	
	100% SPRINKLED	
	100% SPRINKLED	
	100% SPRINKLED	
	100% SPRINKLED	

