CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20242233Address:2206 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, July 15, 2024
Corrective Action Required: 1 Misc			
	 -seal bottom plate penetrations in laundry -address over notched rafters throughout -seal bottom plate penetration E master suite wall -fire block top of fireplace to ceiling space -NE rec room area fire block furr downs ends, complete vertical to horizontal fireblocking every 10' and seal gaps where already done -seal into furr down around beam at rec room/ hallway wall -address over notched exterior wall studs in basement where notched for anchor bolts -address anchor bolts throughout basement not in the middle 1/3 of sill plate -roof perlins not to plans 		

Comments: