

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235740
Address: 2135 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, July 15, 2024

Corrective Action Required:

1 Misc

- address pending driveway inspection
- provide permanent address
- label all non GFCI outlets in unfinished spaces
- pull tabs and covers off all smoke detectors for inspection
- spark ring at fireplace outlet
- handrail at deck stairs
- sod
- splash blocks and sump pump discharge to extend 36" from foundation
- identify sewer tracer wire

Comments: