

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241361
Address: 3228 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, July 15, 2024

Informational:

1 Misc

Garage portal frame inspection only

Corrective Action Required:

2 Misc

- Complete LIB upstairs bedroom 3
- Nail double girder truss together @ bedroom 1
- Strap top plate at bedroom 1 toilet room, less than 24" overlap
- Address exterior corner not tie in to top plate height change and 3 studs minimum @ bedroom 1 and bedroom 3 closet

Comments: