

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232726
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Devon Perry	Passed	Monday, July 15, 2024

Informational:
1 Misc 6-7-24 DP. Air pressure testing

Line D
Z3-C1 Passed
Z3-D1 Passed

Line A
A1-16-010 Passed
A1-A2 Passed
A3-A4 Passed
A5-A4 Passed
A5-B1 Passed
A5-A6 Passed

Line E
A6-E1 Passed

Line B
B2-B1 Passed
B2-B3 Passed

****STILL NEEDING TO BE TESTED****

Line A from MH A6 to MH A8

7-15-24 DP. Line A MH A6 to MH A7 and A7 to MH A8 has both passed air pressure testing. All sanitary has passed air pressure testing now.

Comments: