

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243018
Address: 1905 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Kyle Beard	Failed	Monday, July 15, 2024

Informational:

1	Miscellaneous Correction	PEX ran about 20 feet out toward the curb from the foundation. Okay to cover PEX only
This is a partial pass only		

Comments: