

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231975
Address: 1550 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Alex Fischer	Partial	Tuesday, July 16, 2024

Corrective Action Required:

1	Misc	-Underslab from CT to MDP and MDP to HB PASSED 5/23/24 AF
		-Ufer ground system PASSED 6/14/24 AF
		-Underground electrical for light pole bases PASSED 7/16/24 AF

Comments: