

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241525  
Address: 1909 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, July 16, 2024

Corrective Action Required:

1	Misc	Called Scott no answer, arrived at house at 10:20 no answer.
---	------	--

**Comments:**