

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241770
Address: 3724 SW KNOXVILLE CT, LEES SUMMIT, MO 640823722 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Tuesday, July 16, 2024

Corrective Action Required:

1	Miscellaneous Correction	Exterior sheeting is not fastened down at both top place on unit 3722 N/E corner
---	--------------------------	--

This is a partial inspection only

Comments: