

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241800
Address: 3824 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Tuesday, July 16, 2024

Corrective Action Required:

2	Miscellaneous Correction	Erosion control is damaged at the front of the lot and needs to be replaced or repaired. Full erosion control measures must be maintained until Cofo
---	-----------------------------	--

Comments: