

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20234175  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	Devon Perry	Partial	Tuesday, July 16, 2024

Informational:

1 Misc

10-23-23 DP. Contractor started digging foundation today. There was no Erosion control and rain is on its way tomorrow. I called Steve and he said they would have it installed today.

10-24-23 DP. Silt fence was installed and is currently in good working order.

11-6-23 DP. ESC is currently in good working order.

11-15-23 DP. ESC is currently in good working order.

11-17-23 DP. ESC is currently in good working order.

12-4-23 DP. ESC is still in good working order.

12-12-23 DP. ESC is still in good working order.

4-8-24 DP. ESC is in good working order.

4-18-24 DP. ESC is in good working order.

4-25-24 DP. ESC is in good working order.

5-15-24 DP. ESC is in good working order.

5-31-24 DP. ESC is in good working order.

6-25-24 DP. ESC is in good working order.

7-16-24 DP. ESC is in good working order.

Corrective Action Required:

2            Misc

1-2-24 DP. The silt fence on the north side of the pad is laid over. We need to get this re established and maintained with it being so close to the detention basin.

**Comments:**